



4. Floor Friction Test (마찰계수)

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:56PM

Method: SCOF
Area: 001
Location: 001
Result: 0.57
Temp/Hum: 54 F, 41%



1.

1. Avg = 0.57, Min = 0.56, Max = 0.59



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 2.1 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:38PM

Method: SCOF
Area: 001
Location: 002
Result: 0.55
Temp/Hum: 54 F, 51%



1.

1. Avg = 0.55, Min = 0.55, Max = 0.56



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 1.8 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

99030FDB154CE2556B9678C8754EF8315966020C3AD81A86FE15E0E3FE5AC2E2

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:48PM

Method: SCOF
Area: 001
Location: 003
Result: 0.60
Temp/Hum: 55 F, 47%



1.

1. Avg = 0.60, Min = 0.57, Max = 0.61



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 1.9 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:54PM

Method: DCOF
Area: 001
Location: 001
Result: 0.53
Distance: 08 in.
Temp/Hum: 54 F, 43%



1.

1. Avg = 0.53, Min = 0.48, Max = 0.55



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 2.0 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:37PM

Method: DCOF
Area: 001
Location: 002
Result: 0.51
Distance: 08 in.
Temp/Hum: 54 F, 52%



1.

1. Avg = 0.51, Min = 0.43, Max = 0.61



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 1.8 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

Measurement Result

Regan Scientific Instruments


11/13/2025, 6:48PM

Method: DCOF
Area: 001
Location: 003
Result: 0.54
Distance: 08 in.
Temp/Hum: 55 F, 47%



1.

1. Avg = 0.54, Min = 0.46, Max = 0.66



Device: BOT-3000E (v4.03.00)
Serial No: 00990
Calibration: 09/29/2025
Verification: 11/13/2025, 6:33PM PASS
Meter: 1.9 hrs

Sensor: 02221
Type: Rubber
Manuf. date: 06/19/2025
Ref. offset: —

72813D15781BC77D83A0B503E290A5AA30E779885BE9E79F0BFF58B9254A162C